

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

No. BHAT/PANCHYAT/940/23-24

Date: 19.06.2023

It is certified that an inspection team headed by Mrinal Ganguly, Assistant Engineer, Krishnagar Sub-Division from P.H. Engineering DTE. inspected the KRISHNAGAR PUBLIC SCHOOL at NH-34, PALPARA MORE, KRISHNAGAR-1, NADIA, WEST BENGAL-741102 on 15.06.2023 and found that the KRISHNAGAR PUBLIC SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central /State /U.T. Govt.

The above valid for a period of ...1... Year

Signature with Seal :



Name :

Pradhan  
Bhatjanga Gram Panchayet  
Krishnagar-1 P.S., Nadia

Designation

To,

**KRISHNAGAR PUBLIC SCHOOL (K.P.S.)**

**NH-34, PALPARA MORE,**

**KRISHNAGAR-1, NADIA,**

**PIN-741102, WEST BENGAL**

**GOVERNMENT OF WEST BENGAL**  
**PUBLIC HEALTH ENGINEERING DIRECTORATE**  
**KRISHNAGAR SUB - DISTRICT LABORATORY UNDER KRISHNAGAR SUB - DIVISION**  
**WATER QUALITY TEST REPORT**

Memo No :

*790/KSD*

Ref Memo No :

Date :

*15/6/23*

Date :

PARAMETER	DESIRABLE LIMIT	PERMISSIBLE LIMIT
pH	6.5 to 8.5	NO RELEXATION
TURBIDITY	1 NTU	5 NTU
TOTAL HARDNESS	200 mg/lit	600 mg/lit
IRON	0.3 mg/lit	1.0 mg/lit
ARSENIC	0.01 mg/lit	0.01 mg/lit
TC		0/100 ml
FC		0/100 ml

Sl NO	SOURCE DETAILS	TYPE OF SOURCE	DATE OF SUBMISSION	DATE OF TESTING	pH	TURBIDITY (NTU)	TOTAL HARDNESS (mg/l)	IRON (mg/l)	AS (mg/l)	TC	FC
1	KRISHNAGAR PUBLIC SCHOOL KRISHNAGAR	FILTER	13-06-2023	15-06-2023	7.19	0.69	204	0.14	0.01	0	0

**SAMPLE COLLECTED BY : CONCERNED SCHOOL AUTHORITY**

WATER ANALYST



KRISHNAGAR SUB-DISTRICT LAB  
KRISHNAGAR SUB-DIVISION, P.H.E.Dre.

ASSISTANT ENGINEER



KRISHNAGAR SUB - DIVISION  
P.H. ENGINEERING DTE