

FIRE SAFETY CERTIFICATE

No.

Dated:

Certified that the Krishnagar Public School (name of the building or premises) at R.S. Plot No. 10, LR Plot No. 109 / Khaitan No 1564/ JL No 91, Palpara More, Mouza - Baraihuda, Krishnagar I, Nadia, West Bengal, PIN - 741102 (address) comprised of two blocks with zero basement(s) and four floors (G+3) (upper floors) owned/ occupied by Krishnagar Public School (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified by the officers concerned of Fire Service on 05.08.2023 (date of inspection) in the presence of Mr. Amitava Guha, Director, Krishnagar Public School (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes XII (X/ XII) With effect from 10.08.2023 for a period of 03 years in accordance with rule and subject to compliance of specific conditions.

Issued on 10.08.2023 (date of issue) at Krishnagar (place) by

Signature with Seal: Narayan Das 11/10/23.
Officer-in-charge
Krishnagar Fire Station
W.B.F. & E.S.
 Name : NARAYAN DAS
 Designation : STATION OFFICER
 Name & Address of Department/ Office: W.B.F. & E.S.

To

Krishnagar Public School

Palpara More, Krishnagar, Nadia

West Bengal, PIN - 741102

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

.....
 (reasons to be recorded).

(Name and designation of the authorized signatory)



Government Of West Bengal
Office Of The Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services
Azad Hind Sarak, P.O.:- Ghurni, P.S.:- Kotwali, Pin :- 741103

Memo no.:FES/NAD/46/17

Date: 10-08-2023

From:

Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services

To: Krishnanagar Public School

R.S Plot No- 10, J.L No- 91, L.R No- 109, Mouza- Baruihuda, Palpara More, P.O- Bhatjungla, P.S- Kotwali, Nadia.

Sub: Renewal of Fire Safety Certificate for Existing construction of G+II storied building in the name & style of "Krishnagar Public School" under Education Building at premises no: Plot No:10,J.L No:91,L.R No:109,Mouza: Baruihda Palpara More, P.O:Bhatjungla,P.S:Kotwali, Dist:Nadia,Pin-741102, West Bengal.

This is in reference to your application number 0125191231000095; dated: 02.08.2023.regarding the Renewal of Fire Safety Certificate

for existing G+II storied building in the name & style of "Krishnagar Public School".

The performance of the Fire Fighting system as in corporate in the aforesaid building were test and random found satisfactory working

condition during inspection. On the basis of that this office is releasing renewal of "Fire Safety Certificate " for the aforesaid building.

Moreover to up-keep the Fire Safety measure the following safety measures need to be incorporated.

This is in reference to your application no. 0125191231000095 dated 02-08-2023 regarding the Renewal of Fire Safety Certificate for Existing construction of G+II storied building in the name & style of "Krishnagar Public School" under Education Building at premises no: Plot No:10,J.L No:91,L.R No:109,Mouza: Baruihda Palpara More, P.O:Bhatjungla,P.S:Kotwali, Dist:Nadia,Pin-741102, West Bengal.

This is in reference to your application number 0125191231000095; dated: 02.08.2023.regarding the Renewal of Fire Safety Certificate

for existing G+II storied building in the name & style of "Krishnagar Public School".

The performance of the Fire Fighting system as in corporate in the aforesaid building were test and random found satisfactory working

condition during inspection. On the basis of that this office is releasing renewal of "Fire Safety Certificate " for the aforesaid building.

Moreover to up-keep the Fire Safety measure the following safety measures need to be incorporated.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found

satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Good housekeeping shall always be maintained.
2. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. The Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in the them , Particularly lines above false ceiling & ducts. Electrical safety Audit to be conducted positively by 31st March every years.
5. A fire control room including a close circuit T.V system will have to be installed which observe all floor of the building podium shall be incorporate with the system.
6. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at the venerable of the building.
7. The employees and security staff shall be conversant with installed Fire fighting equipment's of the building and to operate in the event of Fire & testing.
8. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupancy of the building.
9. A crew of trained Fire man under experience officer shall be maintained round the clock for Fire Safety of the building.
10. Arrangement shall have to be made for regular checking , testing and maintains of all the Fire Fighting installation in the building to kept them in perfectly good working condition at all the time.
11. The inertial finish decoration of building shall be made with low flame spread material confirming of I.S specification.
12. The Stand-by pump shall be provided within 03(three) month's from the date of issue of this letter & inform to this office otherwise treated as canceller.
13. P.A. system shall be provided within 03(three) month's from the date of issue of this letter & inform to this office otherwise treated as canceller.
14. U.G.W.R 15000 ltrs existed but shall be provided as per recommend within 03(three) month's from the date of issue of this letter & inform to this office otherwise treated as canceller.
15. The First Aid Fire Fighting arrangement in the style of placing suitable Fire Extinguisher , Fire buckets etc shall be provided where not provided.
16. Periodical flashing of water in the hydrant and Hose reel shall be made to maintain the efficiency working performance of above mention system.
17. The Fire Safety audit to be conducted a regular interval and the be record in the Fire Prevention maintenance register.
18. This Fire Safety Certificate is valid for three years and have to be renewed every three years interval from the date of issue of this letter. In every three years Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, regarding the performance of all the life & Fire Safety arrangement and installation of the building.
19. Any deviation or changes the building in respect of the approved plan drawing , without prior permission from this office this Fire Safety Certificate will be treated cancelled automatically.

Signature Not Verified

Digitally Signed.
Name: SUBRATA GUHA
Date: 10-Aug-2023 12:05:19
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services

Memo No.: FES/NADIA/46/17